

FIRE SAFETY CERTIFICATE


No. 82 / 2024

Certified that the HOLY ANGELS PUBLIC SCHOOL at New Survey No.68/1PT,61, Alagapuram Village, MG Road, Fairlands, Salem West Taluk, Salem District, Salem. 636 016 comprised of Ground Floor, First Floor and Second Floor Owned by HOLY ANGELS PUBLIC SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 03.07.2024 in the presence of **SR. JOYCY AUGUSTINE**, The Principal and that the building is fit for occupancy up to classes X. With effect **from 03.07.2024 for a period of one year** in accordance with rule and subject t

o compliance of specific conditions as appended:-

1. Fire Safety Equipment provided based on NBC Rule.
2. The School Should be maintained neat and clean.
3. Mock Drill Should be conducted periodically.
4. To avoid the storage of in-flammable materials within the school premises.
5. The Storage of LPG cylinder should be maintained safely.
6. The Exit signage board should be maintained through proper fluorescent colour.

Issued on 03.07.2024 at Salem by **Mr. P. Sivakumar, Assistant District Officer, Salem Fire and Rescue Station.**



[Signature] 3/7/24
Assistant District Officer
Fire and Rescue Services
Salem-636 001
Salem District

To,

The Principal,
HOLY ANGELS PUBLIC SCHOOL,
Alagapuram Village, MG Road,
Fairlands, Salem West Taluk,
Salem District, Salem- 636 016